



STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE
04333-0016

JOHN ELIAS BALDACCI
GOVERNOR

DAVID A. COLE
COMMISSIONER

July 26, 2004
Subject: Lubec-Campobello
Pin No. 006893.00
Project No. BH-STP-6893(00)X
Bid Amendment No. 3

Dear Sir/Ms.:

The Department has received the following Requests for Information:

Question 1: There is not enough vertical clearance to set the proposed steel form over the existing steel column.

Response: It is the Departments opinion that there is enough clearance; there is approximately 63.5 feet of vertical clearance from the superstructure to mean low water.

Question 2: What is the clearance under the bridge at high tide?

Response: The vertical clearance under the bridge at mean high tide is approximately 46 feet.

Question 3: What is the maximum velocity of the current based on tidal action?

Response: 4 to 8 knots maximum.

Consider this information prior to submitting your bid on July 28, 2004.

Sincerely,

Scott Bickford
Contracts & Specifications Engineer



PRINTED ON RECYCLED PAPER